

PowerCost Monitor™



Unsupported/Incompatible Meters

FOCUS

Landis & Gyr FOCUS/ALF meter.

(Trilliart Radio often installed)

No infrared (ir) pulse for the sensor to pickup



Plate Cover

Standard Disk meter with AMR plate covering disk.

No location for the sensor to be installed



Elster A3TL Does not transmit the Watt pulse
ANSI (Silver raised port) does not output IR pulse



No Pulse Emitted!

Schlumberger MT200/100 Does not transmit the Watt pulse
ANSI (Silver raised port) does not output IR pulse



